

City of Woodburn

Community Development

Memorandum

| 270 Montgomery Street | | Woodburn, Oregon 97071 | Phone (503) 982-5246 | Fax (503) 982-5244 | | |
|-----------------------|--|--|----------------------|--------------------|--|--|
| Date: | February 28 | 3, 2023 | | | | |
| To: | Melissa Gitt, Building Official | | | | | |
| Cc: | Alyssa Nichols, Permit Technician Dago Garcia, P.E., City Engineer Chris Peck, Triumph Specialty Construction, Inc. Kirk Hall, Drafter/Designer III, Crow Engineering, Inc. | | | | | |
| From: | Colin Cortes | olin Cortes, AICP, CNU-A, Senior Planner CC. | | | | |
| Subject: | Building permit 971-23-000102-STR-02 Townsend Farms Planning Division review | | | | | |

Introduction

On behalf of the Planning Division, I reviewed the building permit application site plans for conformance with the Conditional Use CU 22-02 land use final decision conditions of approval and notes to the applicant related to Townsend Farms industrial freezer tunnel at 960 Young St (applicant's project no. 21441).

The <u>"final decision" document</u> with the conditions of approval remains on the <u>City project</u> <u>webpage</u> or via the City Projects webpage at <<u>www.woodburn-or.gov/projects</u>>.

The building permit application is permit / Accela/ePermitting record no. 971-23-000102-STR-02 (phase 2 of phased permit, the one for vertical construction as distinct from 01 for foundation only).

Below is what the applicant needs to do.

Additional Info Needed

A. Land use Condition G1 from CU 22-02 Attachment 202 isn't met:

"As part of building permit application, the applicant shall submit revised site plans meeting the conditions of approval and obtain Planning Division approval through signoff on permit issuance. The applicant shall submit a cover letter indicating what specific plans sheets or document page numbers demonstrate how the submittal meets each condition."

Re-submittal Process:

- Use a dated cover or transmittal letter to cite and address each Planning Division review item by directing to a plan sheet or document. Specify the building permit record number(s), building letter, plan sheet number(s), and where relevant detail or note number(s), or document page number(s) where conformance is demonstrated, i.e. where the revision or additional information is.
- 2. Provide illustrations and notes through any of plan sheets primarily; however cut or spec sheets or other document types, may substitute when they are the best form for demonstrating conformance.
- Besides submitting two paper copies of revised or additional documentation, upload PDFs of new or revised plans to the applicable Accela building permit record(s).
- 4. Submit revisions through the Building Division per its policies. Do not piecemeal additional information; submit a package of revised and additional information. Do not make direct submittal only to me; the applicant may courtesy copy me or mark materials to my attention while still routing them through the Building Division per its policies.
- 5. Provide demonstrations of conformance through building permit drawings to the max extent feasible such that they remain when the contractor receives site copies of approved plan sets. (If it's not on the plans or on the plans but too vague to act upon, the improvement in question wouldn't be known about or done right away.)
- 6. Feel free to ask me for any clarifications or further direction prior to resubmittal.

B. Regarding Conditions G4a & b:

 "a. When public street improvements, and any fees in lieu of public improvements, are due shall be per WDO 3.01.02E and 4.02.12 unless if and where a condition of approval has more restrictive timing. By this condition, there is more restrictive timing: In any case, they are due no later than by Building Division issuance of first certificate of occupancy (C of O), regardless of deferral, if any, that PW might have approved through 3.01.02E."

WDO 3.02.01E states:

"When all public improvements are due: The construction of all public improvements, their passing City inspections, and acceptance by the City are due no later than by either 5.01.06B in the context of land division final plat application to the City or by building permit issuance, except if (1) the developer applies to the City through the Public Works Department for deferral and (2) the City Administrator or designee issues a document approving and describing a bond or performance guarantee pursuant to Section 4.02.08. Administration of bonding and performance guarantees for improvements that are public defaults to the Public Works Department, and the department shall notify the Community Development Director of deferral applications and any approvals and conditions of approval."

Public Works comments (final decision Attachment 102A), item 12 states, "All public improvements shall be deemed complete prior to issuance of building permit."

Young Street frontage improvements are due, and because of the context per Item B3 below, it's impossible that they are done already. Address the issue.

2. "b. ROW/easements: Recordation of required right-of-way (ROW) and public easements is due by building permit issuance."

Per this condition and G6b, submit PDF copies of the documentation correctly recorded with Marion County:

- a. Conditions CU1a(1) & D1a(1) address ROW.
- b. Condition D1a(2) affirms the streetside public utility easement (PUE) standard.
- c. Public Works comments (final decision Attachment 102A), item 9 addresses on-site PUE(s), and item 11 affirms Condition G4b.
- d. If recordation is yet to begin, see again final decision Note A (final decision p. 12) about timeline.

3. There's no documentation that the applicant applied for and obtained Public Works Department civil engineering plan (CEP) review and approval, i.e. review and approval of construction detail documents for Young Street improvements. Without the applicant forwarding a copy of the civil plan set marked approved by the Public Works Department, Planning Division staff cannot sign off on building permit issuance.

Also regarding CEP, see final decision Notes to Applicant 17a-c (final decision p. 15). Per final decision Attachment 203 (p. 3), CEP submittal is to come with a \$250 Planning Division review fee with payment through Planning Division administrative staff.

- C. Landscaping: The permit set sheet list doesn't list landscaping plans, and one are included. Submit one or more landscape plan sheets per Condition G1 and that conform to the landscaping conditions of approval: CU3b(2), CU4, CU5, CU6, CU7, D1a(3), & D9a.
- D. Fire apparatus access road west: Address Condition D4. Forward a written response from the District that indicates if the condition is relevant or not. If relevant, then illustrate and note conformance through revised site plans. Specify the sheet(s).
- E. Wide walkway: Illustrate and note conformance with Condition D5 through revised site plans. Specify the sheet(s).
- F. Left turn pocket striping: Illustrate and note conformance with Condition D5a through revised site plans. Specify the sheet(s).

G. Parking:

1. The applicant for land use approval (CU 22-02) submitted a draft parking plan on January 19, after Planning Commission staff report publication. Now that staff reviews it closely for conformance, conformance is unclear.

| PARKING REQUIREMENTS | | | | | |
|---|---------------|------------------------|----------|--|--|
| SPACES | MIN. REQUIRED | RATIO | REQUIRED | | |
| EMPLOYEES | 60 | - | | | |
| PARKING REQUIREMENTS PER WOODBURN DEVELOPMENT ORDINANCE (NO. 2603, JUNE 13,2022) | | | | | |
| WAREHOUSE (MOTOR FREIGHT TRANSPORTATION) | 13,885 SF | 1 per 5,000 | 3 | | |
| MANUFACTURING | 22,920 SF | 1 per 800 | 28 | | |
| OFFICE | 4,677 SF | 1 per 850 | 13 | | |
| TOTAL REQUIRED | | | 44 | | |
| TOTAL PROVIDED | | | 85 | | |
| ADA STALLS | | 2 plus 1 VAN STALLS | 3 | | |
| EV STALL | | 5% OF STALLS | 3 | | |
| CARPOOL STALLS | | 5% OF STALLS | 3 | | |
| BICYCLE PARKING | | 15% OF STALLS | 9 | | |

- 2. Regarding the above table excerpted from the parking plan, specify what row numbers in Table 3.05A are cited. It appears that row numbers 50, 55, & 56 are cited. Item 50 has one parking ratio, and rows 55 & 56 share another.
- 3. For all, the parking ratio is a "greater of" standard with three ways to calculate. Provide the analysis showing the ways to calculate parking and which is the greater of them.
- 4. The table breaks out accessory office use distinct from the primary industrial use(s) as if primary office and applied an office rate. Revise to calculate no differently than the industrial primary use(s).
- 5. If there is a difference in result between row numbers 50 and 55/56, specify which one(s) the applicant chooses.
- 6. Illustrate and note conformance with Condition D6 through a revised parking plan. (Submit with the revised building permit plan set.)
- H. Carpool/vanpool: Because total minimum parking ratio is unclear, it remains unclear how WDO Table 3.05C calculates and if the parking plan proposed 3 C/V stalls meet the minimum. Verify the C/V min requirement when addressing Item G in order to confirm conformance with the table through Condition D7.
- I. EV: Because total minimum parking ratio is unclear, it remains unclear how WDO Table 3.05E calculates and if the parking plan proposed 3 EV stalls meet the minimum. Verify the EV min requirement when addressing Item G in order to confirm conformance with the table through Condition D8.

- J. Bicycle parking: The parking plan indicates bicycle parking at 15% of stalls. Because total minimum parking ratio is unclear, it remains unclear how WDO Table 3.05D calculates what 15% would equal. Also, the plan does not indicate racks or other facilities, dimensions, and other information in conformance with WDO 3.05.06C through Condition D9.
- K. Monument sign removal: Address conformance with Condition D10 by revising a site plan sheet to note such. Specify the sheet. (Note that staff reads the condition to mean that removal is due by request for final inspection.)
- L. Lighting: Address conformance with WDO 3.11 through Condition D11 about altered or new exterior lighting: mounting heights (3.11.02B) and hue / color temperature (3.11.02C).
- M. Fire apparatus access road #1: Provide a status update about Condition V1, particularly parts b., c., & e.

Attachment(s):

none