

NOTES:

1. BED PIPE WITH 1"—MINUS SO AS TO CARRY LOAD OF PIPE EVENLY WITHOUT FIXING LOAD ON PIER BLOCKS DIG OUT BELOW BED FOR PIER BLOCKS, AS DIRECTED.
2. BURY HEIGHT: 3-1/2 TO 4 FEET. IF GREATER DEPTH IS REQUIRED EXTENSIONS SHALL BE USED TO ADJUST FH TO PROPER HEIGHT.
3. BACK FILL SHALL BE OF TYPE SPECIFIED.
4. D.I. PIPE BETWEEN VALVE AND FH SHALL BE BY MEANS OF MECHANICAL JOINT WITH MEGALUG PIPE CONNECTORS OR COATED THREADED TIE RODS, AS APPROVED.

HYDRANT: MUELLER SUPER CENTURION 250™ A423 OR M & H RELIANT 129S. REFERENCE TECHNICAL SPEC. SECTION 5070.

